

# SUBMITTAL REVIEW COMMENTS



CITY AND COUNTY OF SAN FRANCISCO  
MUNICIPAL TRANSPORTATION AGENCY

**CONTRACT NAME:** Central Subway Pagoda Palace Demolition      **SUBMITTAL NO:** 01 35 00-001  
**CONTRACT NO:** 1277      **REVIEW CYCLE NO:** 001  
**SUBMITTAL NAME:** Abatement Plan/HMMP      **COMMENTS DATE:** 07/23/2013  
**SPEC SECTION NAME:** Hazardous Materials Procedures (01 35 00)

**DISPOSITION:** (please mark with an "X")

- Approved       Approved as Noted       Approved as Noted – Resubmittal Required  
 Disapproved – Resubmit       Rejected       No Action Required

**COMMENTED BY:** Jeff Kraus/ Sarah Wilson

## REVIEW COMMENTS:

1. The plan indicates the cutting around the structural beams will be performed by "others". Please advise who is considered as "others". In addition, will these "others" be properly trained regarding working around asbestos? What PPE will be used?
2. How does MH Construction plan to dispose of the "regulated" waster (i.e. lead paint)? Will another hauler be used to transport the removed paint? Submit manifests to be used and provide notifications, including requests for pre-abatement meetings and work area inspections by job phase as required by Specification Section 02 13 00.
3. The plan states that "metals and cutting" will be performed by others. How is that? Will RMC handle and ensure their compliance with the HMMP?